

The application does not propose a change in the rights, obligations, or interests of the other joint owners of MP3. In addition, no physical changes to MP3 or operational changes are being proposed.

The proposed amendment, submitted by NNECO on behalf of NEP, would remove references to Montaup in the license and change the number of license holders as stated in the license from 14 to 13. NEP is currently referenced in the license as a licensee, given its existing ownership interest in MP3, and therefore, would not need to be added to the license. These changes are necessary to reflect the proposed transfer.

Pursuant to 10 CFR 50.80, no license, or any right thereunder, shall be transferred, directly or indirectly, through transfer of control of the license, unless the Commission shall give its consent in writing. The Commission will approve an application for the direct transfer of a license, if the Commission determines that the proposed transferee is qualified to hold the license, and that the transfer is otherwise consistent with applicable provisions of law, regulations, and orders issued by the Commission pursuant thereto. An application for approval of an indirect license transfer will be approved if the Commission determines that the underlying transaction effecting the indirect transfer will not affect the qualifications of the holder of the license, and that the indirect transfer is otherwise consistent with applicable provisions of law, regulations, and orders issued by the Commission pursuant thereto.

Before issuance of the proposed conforming license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

As provided in 10 CFR 2.1315, unless otherwise determined by the Commission with regard to a specific application, the Commission has determined that any amendment to the license of a utilization facility which does no more than conform the license to reflect the transfer action involves no significant hazards consideration. No contrary determination has been made with respect to this specific license amendment application. In light of the generic determination reflected in 10 CFR 2.1315, no public comments with respect to significant hazards considerations are being solicited, notwithstanding the general comment procedures contained in 10 CFR 50.91.

The filing of requests for hearing and petitions for leave to intervene, and

written comments with regard to the license transfer application, are discussed below.

By February 7, 2000, any person whose interest may be affected by the Commission's action on the application may request a hearing, and, if not the applicants, may petition for leave to intervene in a hearing proceeding on the Commission's action. Requests for a hearing and petitions for leave to intervene should be filed in accordance with the Commission's rules of practice set forth in Subpart M, "Public Notification, Availability of Documents and Records, Hearing Requests and Procedures for Hearings on License Transfer Applications," of 10 CFR Part 2. In particular, such requests and petitions must comply with the requirements set forth in 10 CFR 2.1306, and should address the considerations contained in 10 CFR 2.1308(a). Untimely requests and petitions may be denied, as provided in 10 CFR 2.1308(b), unless good cause for failure to file on time is established. In addition, an untimely request or petition should address the factors that the Commission will also consider, in reviewing untimely requests or petitions, set forth in 10 CFR 2.1308(b)(1)–(2).

Requests for a hearing and petitions for leave to intervene should be served upon Edward Berlin, Esq., Kenneth G. Jaffe, Esq., and Scott P. Klurfeld, Esq., Swidler Berlin Shereff Friedman, LLP, 3000 K Street, NW., Suite 300, Washington, DC 20007–5116, attorneys for New England Power Company; Thomas G. Dignan, Jr., Esq., Ropes & Gray, One International Place, Boston, Massachusetts, 02110–2624, attorney for Montaup Electric Company; Lillian M. Cuoco, Esq., Senior Nuclear Counsel, Northeast Utilities Service Company, 107 Selden Street, Berlin, Connecticut, 06037, attorney for Northeast Nuclear Energy Company; the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555 (e-mail address for filings regarding license transfer cases only: OGCLT@NRC.gov); and the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001, Attention: Rulemakings and Adjudications Staff, in accordance with 10 CFR 2.1313.

The Commission will issue a notice or order granting or denying a hearing request or intervention petition, designating the issues for any hearing that will be held and designating the Presiding Officer. A notice granting a hearing will be published in the **Federal Register** and served on the parties to the hearing.

As an alternative to requests for hearing and petitions to intervene, by February 17, 2000 persons may submit written comments regarding the license transfer application, as provided for in 10 CFR 2.1305. The Commission will consider and, if appropriate, respond to these comments, but such comments will not otherwise constitute part of the decisional record. Comments should be submitted to the Secretary, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001, Attention: Rulemakings and Adjudications Staff, and should cite the publication date and page number of this **Federal Register** notice.

For further details with respect to this action, see the application dated June 15, 1999, as supplemented July 20, September 3, and November 29, 1999, submitted under cover of letters dated June 15, July 20, September 3, and November 29, 1999, respectively, which are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW, Washington, DC, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site, <http://www.nrc.gov>.

Dated at Rockville, Maryland this 12th day of January 2000.

For the Nuclear Regulatory Commission.

**Victor Neres,**

*Senior Project Manager, Section 2, Project Directorate I, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 00–1172 Filed 1–18–00; 8:45 am]

BILLING CODE 7590–01–P

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50–361 and 50–362]

### **Southern California Edison Company, San Onofre Nuclear Generating Station, Units 2 and 3; Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing**

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating Licenses Nos. NPF–10 and NPF–15 issued to Southern California Edison Company (SCE, the licensee) for operation of the San Onofre Nuclear Generating Station (SONGS), Units 2 and 3, located in San Diego County, California.

The proposed amendments would revise the SONGS, Units 2 and 3,

Technical Specification (TS) relating to the Auxiliary Feedwater (AFW) System. Specifically, the licensee proposed to revise TS 3.7.5 to add a note that states: "The steam driven AFW pump is OPERABLE when running and controlled manually to support plant start-ups, plant shut-downs, and AFW pump and valve testing."

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendments would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Will operation of the facility in accordance with this proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

Probabilistic analyses have been performed in support of declaring P140 operable when the pump is manually actuated and operating.

The results show that, considering P-140 to be in test for an entire year, the core damage risk of a Main Steam Line Break/Feedwater Line Break (MSLB/FWLB) slightly increases (4.3E-8/yr) while the risk due to other initiating events decreases (3E-7/yr). The net core damage impact of P-140 in test for an entire year is a Core Damage Frequency (CDF) decrease of 2E-7/yr. Having P140 operating instead of being in standby increases its reliability. This increased reliability reduces the risk due to other initiating events, such as loss of main feedwater, medium and small Loss of Coolant Accidents (LOCAs), Steam Generator Tube Rupture (SGTR), and Loss of Offsite Power (LOP), which require Auxiliary Feedwater (AFW) and which occur with much greater frequency than MSLB/FWLB. With the overall CDF reduction a result of considering P140 being in a test configuration for an entire year, the actual cumulative risk incurred is the weighted fraction that P140 is in the test configuration over a year period. Based on past experience, the pump is running in manual approximately 500 minutes/year, which results in an annual net cumulative CDF reduction on the order of

2E-10/yr due to running P140 in the manual mode.

Therefore, the operation of the facility in accordance with this proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Will operation of the facility in accordance with this proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

This change does not involve a plant hardware modification or allow the operation of any plant equipment in any way other than originally designed. This change only affects the administrative tracking of the turbine-driven AFW pump when the steam driven AFW pump is operating in the manual mode.

Therefore, the operation of the facility in accordance with this proposed change will not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Will operation of the facility in accordance with this proposed change involve a significant reduction in a margin of safety?

Response: No.

Pump history shows the pump is run approximately 500 minutes per year. In all cases except for the one postulated scenario of the Main Steam Isolation Signal followed by an Emergency Feedwater Actuation Signal the turbine-driven AFW pump is not susceptible to being tripped. Also, this postulated scenario does not affect the capability of the motor-driven AFW pumps.

Even though there is a small increase in the CDF from the AFW steam driven pump operating in manual mode based on the possibility of a MSLB/FWLB, also considering other initiating events results in an annual net cumulative CDF reduction on the order of 2E-10/yr due to P140 running in the manual mode.

Therefore, the operation of the facility in accordance with this proposed change does not involve a significant reduction in the margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would

result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the **Federal Register** a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this **Federal Register** notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By February 17, 2000, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>). If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing

Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) The nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any

limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Douglas K. Porter, Esquire, Southern California Edison Company, 2244 Walnut Grove Avenue, Rosemead, California 91770, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendments dated January 2, 1998, as supplemented December 13, 1999, which are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>).

Dated at Rockville, Maryland, this 12th day of January 2000.

For the Nuclear Regulatory Commission.

**L. Raghavan,**

*Senior Project Manager, Section 2, Project Directorate IV & Decommissioning, Division of Licensing Project Management, Office of Nuclear Reactor Regulation*

[FR Doc. 00-1174 Filed 1-18-00; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-361 and 50-362]

### **Southern California Edison Company San Onofre Nuclear Generating Station, Units 2 and 3; Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing**

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating Licenses Nos. NPF-10 and NPF-15 issued to Southern California Edison Company (SCE, the licensee) for operation of the San Onofre Nuclear Generating Station (SONGS), Units 2 and 3, located in San Diego County, California.

The proposed amendments would revise the SONGS, Units 2 and 3, Technical Specification (TS) related to the containment isolation valves. Specifically, the licensee proposed a revision to TS 3.6.3 to extend the completion times for Section D.1 and D.2 valves from 4 hours to the applicable limiting condition for operation time pertaining to the engineered safety feature system in which the valve is installed.

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendments would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant