

examinations on March 31, 2002, the follow-on cycle will end on March 31, 2004. Future requalification cycles will run from April 1 to March 31.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (66 FR 38328).

This exemption is effective upon issuance and expires on March 8, 2003.

Dated at Rockville, Maryland, this 10th day of September 2001.

For the Nuclear Regulatory Commission.

Bruce A. Boger,

Director, Division of Inspection Program Management, Office of Nuclear Reactor Regulation.

[FR Doc. 01-23150 Filed 9-14-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[50-458]

Entergy Operations, Inc.; River Bend Station; Environmental Assessment and Finding of No Significant Impact

The U.S. Nuclear Regulatory Commission (the NRC) is considering issuance of an exemption from 10 CFR part 50, Appendix G for Facility Operating License No. NPF-47, issued to Entergy Operations, Inc. (the licensee), for operation of the River Bend Station, Unit 1 (RBS) located in West Feliciana Parish, Louisiana. Therefore, as required by 10 CFR 51.21, the NRC is issuing this environmental assessment and finding of no significant impact.

Environmental Assessment

Identification of the Proposed Action

The proposed action would exempt the licensee from certain provisions of 10 CFR part 50, Appendix G. Pursuant to 10 CFR part 50, Appendix G, pressure-temperature limits (P-T) are required to be established for reactor pressure vessels (RPVs) during normal operating and hydrostatic or leak rate testing conditions. Specifically, 10 CFR part 50, Appendix G, states, “***[t]he appropriate requirements on both the pressure-temperature limits and the minimum permissible temperature must be met for all conditions.” Appendix G to 10 CFR part 50 specifies that the requirements for these limits are the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (the Code), Section XI, Appendix G limits.

The proposed action would substitute ASME Code Case N-640 for specific

requirements in 10 CFR part 50, Appendix G. Code Case N-640, “Alternative Reference Fracture Toughness for Development of P-T Limit Curves Section XI, Division 1,” permits the use of an alternative reference fracture toughness (K_{Ic} fracture toughness curve instead of the K_{Ia} fracture toughness curve) for RPV materials in determining the P-T limits. Since the K_{Ic} fracture toughness curve shown in ASME Code Section XI, Appendix A, Figure A-4200-1 provides greater allowable fracture toughness than the corresponding K_{Ia} fracture toughness curve of ASME Code Section XI, Appendix G, Figure G-2210-1, using the K_{Ic} fracture toughness, as permitted by Code Case N-640, in establishing the P-T limits would be less conservative than the methodology currently endorsed by 10 CFR part 50, Appendix G. Considering this, an exemption to apply the Code Case would be required by 10 CFR 50.60. Accordingly, the licensee requested an exemption from the requirements in 10 CFR part 50, Appendix G.

Use of the K_{Ic} curve in determining the lower bound fracture toughness in the development of P-T operating limits is more technically correct than the K_{Ia} curve, since the rate of loading during a heatup or cooldown is slow and is more representative of a static condition than a dynamic condition. The K_{Ic} curve appropriately implements the use of static initiation fracture toughness behavior to evaluate the controlled heatup and cooldown process relative to an RPV. The ASME Code Section XI, Appendix G, procedure was conservatively developed based on the level of knowledge existing in 1974 concerning RPV materials and the estimated effects of operation. Since 1974, the level of knowledge about these topics has been greatly expanded. The NRC staff concludes that this increased knowledge permits relaxation of the ASME Code Section XI, Appendix G requirements by applying K_{Ic} fracture toughness, as permitted by Code Case N-640, while maintaining, pursuant to 10 CFR 50.12(a)(2)(ii), the underlying purpose of the ASME Code and the NRC regulations to ensure an acceptable margin of safety.

The proposed action is in accordance with the licensee's application for amendment and exemption dated January 24, 2001, as supplemented by letters dated July 2, and August 6 and 20, 2001, and is needed to support the technical specification (TS) amendment that is contained in the same submittal and is being processed separately. The proposed TS amendment will revise the P-T limits of TS 3.4.11, RCS [Reactor

Coolant System] Pressure and Temperature Limits,” related to the heatup, cooldown, and inservice test limitations for the RCS to a maximum of 16 Effective Full Power Years (EFPY). The proposed action replaces TS Figure 3.4-11, “Minimum Temperature Required Vs. RCS Pressure,” with recalculated RCS P-T limits based, in part, on the alternative methodology in Code Case N-640.

The Need for the Proposed Action

The revised P-T limits are needed to allow required reactor vessel hydrostatic and leak tests to be performed at a significantly lower temperature. These tests are to be performed during the upcoming refueling outage scheduled to commence in September 2001. The lower temperature for the tests can reduce refueling outage critical path time by reducing or eliminating the heatup time to achieve required test conditions.

Environmental Impacts of the Proposed Action

The NRC has completed its evaluation of the proposed action and concludes that the exemption and associated license amendment described above would provide an adequate margin of safety against brittle failure of the RBS reactor vessel. The lower temperature, is also safer for test inspectors due to lower ambient drywell temperatures and could result in lower radiological dose due to increased inspection effectiveness at the lower temperature.

The proposed action will not significantly increase the probability or consequences of accidents, no changes are being made in the types of any effluents that may be released off site, and there is no significant increase in occupational or public radiation exposure. Therefore, there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential non-radiological impacts, the proposed action does not have a potential to affect any historic sites. It does not affect non-radiological plant effluents and has no other environmental impact. Therefore, there are no significant non-radiological environmental impacts associated with the proposed action.

Accordingly, the NRC concludes that there are no significant environmental impacts associated with the proposed action.

Environmental Impacts of the Alternatives to the Proposed Action

As an alternative to the proposed action, the staff considered denial of the

proposed action (i.e., the “no-action” alternative). Denial of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

Alternative Use of Resources

This action does not involve the use of any different resource than those previously considered in the “Final Environmental Statement,” NUREG-1073, January 1985, for the RBS.

Agencies and Persons Consulted

On August 13, 2001, the staff consulted with the Louisiana State official, Ms. Soumaya Ghosn of the Louisiana Department of Environmental Quality, Radiation Protection Division, regarding the environmental impact of the proposed action. The State official had no comments.

Finding of No Significant Impact

On the basis of the environmental assessment, the NRC concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the NRC has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee’s letter dated January 24, 2001, as supplemented by letters dated July 2, and August 6 and 20, 2001. Documents may be examined, and/or copied for a fee, at the NRC’s Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Library component on the NRC web site, <http://www.nrc.gov> (the Public Electronic Reading Room). If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC PDR Reference staff at 1-800-397-4209, or 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 7th day of September, 2001.

For the Nuclear Regulatory Commission,
Robert E. Moody,

Project Manager, Section 1, Project Directorate IV, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 01-23149 Filed 9-14-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket 72-30]

Maine Yankee Atomic Power Company (MYAPC) Maine Yankee Independent Spent Fuel Storage Installation (ISFSI) Issuance of Environmental Assessment and Finding of No Significant Impact

The U.S. Nuclear Regulatory Commission (NRC or Commission) is considering issuance of an exemption, pursuant to 10 CFR 72.7, from specific provisions of 10 CFR 72.212(a)(2), 72.212(b)(2)(i), 72.212(b)(7), and 72.214 to MYAPC. The requested exemption would allow MYAPC to deviate from the requirements of Certificate of Compliance No. 1015 (the Certificate), Appendix A, Surveillance Requirement (SR) 3.1.2.1, “CANISTER Vacuum Drying Pressure,” and SR 3.1.3.1, “CANISTER Helium Backfill Pressure,” which provide the surveillance frequencies for verifying the drying pressure and backfill pressure are within limits. The requested exemption would allow the surveillances to be performed “Prior to TRANSPORT OPERATIONS” instead of “Once within 10 hours . . . after completion of CANISTER draining,” which is required by the Certificate.

Environmental Assessment (EA)

Identification of Proposed Action: By letter dated August 9, 2001, MYAPC requested an exemption from the requirements of 10 CFR 72.212(b)(2)(i), 72.212(b)(7), and 72.214 to deviate from the requirements of Certificate of Compliance No. 1015, Appendix A, SR 3.1.2.1 and SR 3.1.3.1. Staff has also considered an exemption from 10 CFR 72.212(a)(2). MYAPC is a general licensee, authorized by NRC to use spent fuel storage casks approved under 10 CFR Part 72, Subpart K.

MYAPC plans to use the NAC-UMS Cask System to store spent nuclear fuel, generated at the Maine Yankee Atomic Power Station, at an ISFSI located in Wiscasset, Maine, approximately 1200 feet north of the reactor plant. The Maine Yankee ISFSI has been constructed for interim dry storage of spent nuclear fuel.

By exempting MYAPC from 10 CFR 72.212(a)(2), 72.212(b)(2)(i), 72.212(b)(7), and 72.214, MYAPC will be authorized to delay performance of SR 3.1.2.1, “CANISTER Vacuum Drying Pressure,” and SR 3.1.3.1, “CANISTER Helium Backfill Pressure,” which provide the surveillance frequencies for verifying the drying pressure and backfill pressure are within limits.

The surveillances, SR 3.1.2.1 and SR 3.1.3.1, shall be performed “Prior to TRANSPORT OPERATIONS.”

The surveillance frequencies above would be in lieu of those in the current Certificate of Compliance No. 1015, Rev. 1, Appendix A, SR 3.1.2.1 and SR 3.1.3.1. The definition of TRANSPORT OPERATIONS is provided in section A 1.1 of Certificate of Compliance No. 1015, Rev. 1, Appendix A (ADAMS Accession #ML010260245). The proposed action before the Commission is whether to grant this exemption under 10 CFR 72.7.

On February 20, 2001, NRC approved Amendment 1 to the NAC-UMS Certificate of Compliance, which provided, in part, a change to Limiting Condition for Operation (LCO) 3.1.1 allowing longer times for spent fuel cask loading operations based on the reduced canister heat loads. The Amendment application did not include a corresponding revision to the surveillance frequencies, in SR 3.1.2.1 and SR 3.1.3.1 and, as a result, the surveillance frequencies were not revised.

The NRC staff has reviewed the exemption request and determined that the revised surveillance frequencies are consistent with the safety analyses previously reviewed for Amendment 1, and would have no impact on the design basis and would not be inimical to public health and safety.

Need for the Proposed Action: NAC International, the owner of the NAC-UMS design, requested Amendment 2 to the Certificate on October 17, 2000. This application, as supplemented, would correct the inconsistencies with SR 3.1.2.1 and SR 3.1.3.1. However, the rulemaking on this amendment will not be completed in time to support the planned schedule for Maine Yankee cask loading. Therefore, this error in not revising the inconsistent surveillance frequencies may provide insufficient surveillance frequency times to avoid unnecessarily entering into the Required Actions for the associated LCOs 3.1.2 and 3.1.3. The NRC is proposing to grant this exemption based on the staff’s technical review of information submitted by MYAPC.

Environmental Impacts of the Proposed Action: The potential environmental impact of using the NAC-UMS system was initially presented in the EA for the Final Rule to add the NAC-UMS to the list of approved spent fuel storage casks in 10 CFR 72.214 (65 FR 62581 (October 19, 2000)).

The staff performed a safety evaluation of the proposed exemption.