

to the Field of Opera." The remainder of this meeting, from 9 a.m.–1 p.m. and from 2:30 p.m.–5 p.m., will be closed.

Museums (application review): August 1–4, 2006 in Room 716. This meeting, from 9 a.m. to 5:30 p.m. on August 1st–3rd and from 9 a.m. to 3 p.m. on August 4th, will be closed.

Theater (application review): August 1–4, 2006 in Room 730. This meeting, from 9 a.m. to 5 p.m. on August 1st–3rd and from 9 a.m. to 3 p.m. on August 4th, will be closed.

Literature (application review): August 9–11, 2006 in Room 714. A portion of this meeting, from 12 p.m.–1 p.m. on August 11th, will be open to the public for a policy discussion. The remainder of the meeting, from 9 a.m. to 6 p.m. on August 9th–10th, from 9 a.m. to 12 p.m. and from 1 p.m. to 4:30 p.m. on August 11th, will be closed.

AccessAbility (application review): August 28, 2006. This meeting, which will be held by teleconference from 2 p.m.–3 p.m., will be closed.

The closed portions of meetings are for the purpose of Panel review, discussion, evaluation, and recommendations on financial assistance under the National Foundation on the Arts and the Humanities Act of 1965, as amended, including information given in confidence to the agency. In accordance with the determination of the Chairman of April 8, 2005, these sessions will be closed to the public pursuant to subsection (c)(6) of section 552b of Title 5, United States Code.

Any person may observe meetings, or portions thereof, of advisory panels that are open to the public, and if time allows, may be permitted to participate in the panel's discussions at the discretion of the panel chairman. If you need special accommodations due to a disability, please contact the Office of AccessAbility, National Endowment for the Arts, 1100 Pennsylvania Avenue, NW., Washington, DC 20506, 202/682–5532, TDY–TDD 202/682–5496, at least seven (7) days prior to the meeting.

Further information with reference to these meetings can be obtained from Ms. Kathy Plowitz-Worden, Office of Guidelines & Panel Operations, National Endowment for the Arts, Washington, DC 20506, or call 202/682–5691.

Dated: July 12, 2006.

Kathy Plowitz-Worden,

*Panel Coordinator, Panel Operations,
National Endowment for the Arts.*

[FR Doc. E6–11301 Filed 7–17–06; 8:45 am]

BILLING CODE 7537–01–P

NATIONAL SCIENCE FOUNDATION

Notice of the Availability of Finding of No Significant Impact for a Marine Geophysical Survey in the Arctic Ocean

AGENCY: National Science Foundation.

ACTION: Notice of availability of a Finding of No Significant Impact for proposed activities in the Arctic Ocean.

SUMMARY: The National Science Foundation gives notice of the availability of a Finding of No Significant Impact for proposed activities in the Arctic Ocean.

The Office of Polar Programs (OPP) has prepared an Environmental Assessment of a marine geophysical study by the Coast Guard cutter *Healy* in the western Canada Basin, Chukchi Borderland and Mendeleev Ridge, July–August–September 2006. Given the United States Arctic Program's mission to support polar research, the proposed action is expected to result in substantial benefits to science.

ADDRESSES: Copies of the Finding of No Significant Impact and the Environmental Assessment are available upon request from: Dr. Polly A. Penhale, National Science Foundation, Office of Polar Programs, 4201 Wilson Blvd., Suite 755, Arlington, VA 22230. Telephone: (703) 292–8033.

SUPPLEMENTARY INFORMATION: The National Science Foundation prepared a draft Environmental Impact Assessment (EA) for a marine geophysical survey in the western Canada Basin, Chukchi Borderland and Mendeleev Ridge and solicited public comments (**Federal Register:** March 8, 2006, Vol. 71, No. 45, Page 11681). The National Science Foundation has prepared a Finding of No Significant Impact (FONSI) based on this EA, in accordance with CEQ regulations § 1500–1508 and 45 CFR part 640. It was determined that the proposed activity would not result in a significant impact on the quality of the human environment within the meaning of the National Environmental Policy Act (NEPA) of 1969. Therefore, a FONSI was issued, and no environmental impact statement is required.

Copies of the FONSI and the Environmental Assessment entitled, Environmental Assessment of a Marine Geophysical Survey by the USCG *Healy* of the Western Canada Basin, Chukchi Borderland and Mendeleev Ridge, Arctic Ocean, July–August 2006, are available upon request from: Dr. Polly A. Penhale, National Science Foundation, Office of Polar Programs,

4201 Wilson Blvd., Suite 755, Arlington, VA 22230. Telephone: (703) 292–8033.

Polly A. Penhale,

Environmental Officer, Office of Polar Programs, National Science Foundation.

[FR Doc. 06–6274 Filed 7–17–06; 8:45 am]

BILLING CODE 7555–01–M

NATIONAL TRANSPORTATION SAFETY BOARD

Notice of Meeting; Sunshine Act

TIME AND DATE: 9:30 a.m., July 25, 2006.

PLACE: NTSB Conference Center, 429 L'Enfant Plaza SW., Washington, DC 20594.

STATUS: The one item is open to the public.

MATTER TO BE CONSIDERED: 7755A, *Marine Accident Report*—Capsizing and Sinking of the New York State-Certificated Vessel Ethan Allen at Lake George, New York, on October 2, 2005.

NEWS MEDIA CONTACT: Terry Williams, Telephone: (202) 314–6100.

Individuals requesting specific accommodations should contact Chris Bisett at (202) 314–6305 by Friday, July 21, 2006.

The public may view the meeting via a live or archived webcast by accessing a link under "News & Events" on the NTSB home page at <http://www.nts.gov>.

FOR FURTHER INFORMATION CONTACT: Vicky D'Onofrio, (202) 314–6410.

Dated: July 14, 2006.

Vicky D'Onofrio,

Federal Register Liaison Officer.

[FR Doc. 06–6349 Filed 7–14–06; 2:25 am]

BILLING CODE 7533–01–M

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50–272 and 50–311]

PSEG Nuclear LLC; Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (NRC or the Commission) is considering issuance of amendments to Facility Operating License Nos. DPR–70 and DPR–75 issued to PSEG Nuclear LLC (the licensee) for operation of the Salem Nuclear Generating Station (Salem), Unit Nos. 1 and 2, located in Salem County, New Jersey.

The proposed amendments would revise the Salem Technical Specifications (TSs) to eliminate certain Surveillance Requirements (SRs) for containment isolation valves. The proposed changes are to delete SR 4.6.3.1.1 and SR 4.6.3.1 for Salem Unit Nos. 1 and 2, respectively. These SRs require a complete valve stroke and stroke time measurement when a valve is returned to service after maintenance, repair, or replacement work. The proposed changes are intended to minimize unnecessary testing and plant transients. Other Salem TS containment isolation valve SRs will ensure that the valves remain operable.

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in Title 10 of the *Code of Federal Regulations* (10 CFR), section 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed amendment would revise the Technical Specification (TS) Surveillance Requirements (SRs) for containment isolation valves, consistent with NUREG-1431, "Standard Technical Specifications, Westinghouse Plants." SRs are not initiators to any accident previously evaluated. Consequently, the probability of an accident previously evaluated is not significantly increased. The equipment specified in the Limiting Conditions for Operation is still required to be operable and capable of performing the accident mitigation functions assumed in the accident analysis. By performing the analysis, valve operability is maintained. This equipment will continue to be tested in a manner and at a frequency to give confidence that the equipment can perform its intended safety function. As a result, the proposed SR changes do not significantly affect the consequences of any accident previously evaluated.

Therefore, the proposed changes do not involve a significant increase in the probability or radiological consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated in the Updated Final Safety Analysis Report. No new accident scenarios, failure mechanisms, or limiting single failures are introduced as a result of the proposed changes. Specifically, no new hardware is being added to the plant as part of the proposed change, no existing equipment is being modified, and no significant changes in operations are being introduced (only certain post-maintenance testing is eliminated leaving operation functions unchanged).

Therefore, the proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

The proposed changes will not alter any assumptions, initial conditions, or results of any accident analyses. The proposed changes do not affect the operational limits or the physical design of the containment isolation valves. The containment isolation valves will remain capable of performing their design function. Unnecessary testing and associated plant transients will be minimized by the proposed changes. Therefore, the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day period provided that its final determination is that the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period should circumstances change during the 30-day comment period such that failure to act in a

timely way would result, for example, in derating or shutdown of the facility. Should the Commission take action prior to the expiration of either the comment period or the notice period, it will publish in the **Federal Register** a notice of issuance. Should the Commission make a final no significant hazards consideration determination, any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this **Federal Register** notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1F21, 11555 Rockville Pike (first floor), Rockville, Maryland.

The filing of requests for a hearing and petitions for leave to intervene is discussed below. Within 60 days after the date of publication of this notice, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.309, which is available at the Commission's PDR, located at One White Flint North, Public File Area O1F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly-available records will be accessible from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or a presiding officer designated by the Commission or by the Chief Administrative Judge of the Atomic Safety and Licensing Board

Panel, will rule on the request and/or petition; and the Secretary or the Chief Administrative Judge of the Atomic Safety and Licensing Board will issue a notice of a hearing or an appropriate order.

As required by 10 CFR 2.309, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements: (1) The name, address and telephone number of the requestor or petitioner; (2) the nature of the requestor's/petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the requestor's/petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the requestor's/petitioner's interest. The petition must also identify the specific contentions which the petitioner/requestor seeks to have litigated at the proceeding.

Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner/requestor shall provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner/requestor must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. The petition must include sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner/requestor who fails to satisfy these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing.

If a hearing is requested, the Commission will make a final determination on the issue of no

significant hazards consideration. The final determination will serve to decide when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

Nontimely requests and/or petitions and contentions will not be entertained absent a determination by the Commission or the presiding officer of the Atomic Safety and Licensing Board that the petition, request and/or the contentions should be granted based on a balancing of the factors specified in 10 CFR 2.309(c)(1)(i)-(viii).

A request for a hearing or a petition for leave to intervene must be filed by: (1) First class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; (2) courier, express mail, and expedited delivery services: Office of the Secretary, Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, Attention: Rulemaking and Adjudications Staff; (3) e-mail addressed to the Office of the Secretary, U.S. Nuclear Regulatory Commission, HEARINGDOCKET@NRC.GOV; or (4) facsimile transmission addressed to the Office of the Secretary, U.S. Nuclear Regulatory Commission, Washington, DC, Attention: Rulemakings and Adjudications Staff at (301) 415-1101, verification number is (301) 415-1966. A copy of the request for hearing and petition for leave to intervene should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and it is requested that copies be transmitted either by means of facsimile transmission to 301-415-3725 or by e-mail to OGCMailCenter@nrc.gov. A copy of the request for hearing and petition for leave to intervene should also be sent to Jeffrie J. Keenan, Esquire, Nuclear Business Unit—N21, P.O. Box 236, Hancocks Bridge, NJ 08038, attorney for the licensee.

For further details with respect to this action, see the application for amendment dated September 26, 2005, which is available for public inspection at the Commission's PDR, located at One White Flint North, File Public Area

O1F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the ADAMS Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR reference staff by telephone at 1-800-397-4209, 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 12th day of July 2006.

For the Nuclear Regulatory Commission.

Stewart N. Bailey,

Senior Project Manager, Plant Licensing Branch 1-2, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. E6-11319 Filed 7-17-06; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-244]

R.E. Ginna Nuclear Power Plant, LLC; R.E. Ginna Nuclear Power Plant; Notice of Issuance of Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (Commission) has issued Amendment No. 97 to Renewed Facility Operating License No. DPR-18, issued to R.E. Ginna Nuclear Power Plant, LLC (the licensee), which revised the License and Technical Specifications for operation of the R.E. Ginna Nuclear Power Plant located in Wayne County, New York. The amendment is effective as of the date of issuance.

The amendment modified the License and Technical Specifications to authorize an increase in the licensed rated thermal power by 16.8 percent from 1520 megawatts thermal (MWt) to 1775 MWt. This level of power increase is considered an extended power uprate.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for a Hearing in connection with this action was published in the **Federal Register** on September 22, 2005 (70 FR 55633). No