

NUCLEAR REGULATORY COMMISSION

[NRC-2010-0294]

Criteria for Nominating Materials Licensees for the U.S. Nuclear Regulatory Commission's Agency Action Review Meeting**AGENCY:** Nuclear Regulatory Commission.**ACTION:** Request for comment.

SUMMARY: It is the policy of the U.S. Nuclear Regulatory Commission (NRC) to have its senior managers conduct an annual Agency Action Review Meeting (AARM). The AARM is an integral part of the evaluative process used by the agency to ensure the operational safety performance of licensees. As a part of the AARM process, the NRC reviews the agency's actions concerning fuel cycle facilities and other materials licensees (including Agreement State licensees) with significant performance concerns. In 2002, the NRC developed criteria for determining materials licensees that would be discussed at the AARM. The NRC revised the criteria to incorporate NRC's current policies and procedures in 2008. The criteria that is currently used to determine materials licensees that will be discussed at the AARM may be found in Enclosure 2 of SECY-08-0135, "Revision of the Criteria for Identifying Nuclear Materials Licensees for Discussion at the Agency Action Review Meeting," dated September 16, 2008 (ADAMS Accession Number: ML082480564).

Currently, the NRC is considering revisions to this criteria for Identifying Materials Licensees for Discussion at the AARM. A draft revised criterion found in the **SUPPLEMENTARY INFORMATION** below provides an additional criterion to address licensees previously discussed at the AARM. The reason this additional criterion has been added is to allow NRC's senior management to address why the previously identified issues are not being resolved. The NRC is seeking public comment on this revised criterion.

DATES: Please submit comments regarding the proposed criteria, by October 25, 2010. Comments received after this date will be considered if practical to do so, but the NRC staff is able to ensure consideration only for those comments received on or before this date.

ADDRESSES: You may submit comments by any one of the following methods. Please include Docket ID NRC-2010-0294 in the subject line of your comments. Comments submitted in

writing or in electronic form will be posted on the NRC Web site and on the Federal rulemaking Web site, <http://www.regulations.gov>. Because your comments will not be edited to remove any identifying or contact information, the NRC cautions you against including any information in your submission that you do not want to be publicly disclosed.

The NRC requests that any party soliciting or aggregating comments received from other persons for submission to the NRC inform those persons that the NRC will not edit their comments to remove any identifying or contact information, and therefore, they should not include any information in their comments that they do not want publicly disclosed.

Federal Rulemaking Web site: Go to <http://www.regulations.gov> and search for documents filed under Docket ID NRC-2010-0294. Address questions about NRC dockets to Carol Gallagher 301-492-3668; e-mail Carol.Gallagher@nrc.gov.

Mail comments to: Cindy Bladey, Chief, Rules, Announcements and Directives Branch (RADB), Division of Administrative Services, Office of Administration, Mail Stop: TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by fax to RADB at (301) 492-3446.

You can access publicly available documents related to this notice using the following methods:

NRC's Public Document Room (PDR): The public may examine and have copied, for a fee, publicly available documents at the NRC's PDR, Public File Area O1 F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland.

NRC's Agencywide Documents Access and Management System (ADAMS): Publicly available documents created or received at the NRC are available electronically at the NRC's Electronic Reading Room at <http://www.nrc.gov/reading-rm/adams.html>. From this page, the public can gain entry into ADAMS, which provides text and image files of NRC's public documents. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC's PDR reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr.resource@nrc.gov. The Proposed Criteria for Identifying Materials Licensees for Discussion at the AARM is also available electronically under ADAMS Accession Number ML101900346.

Federal Rulemaking Web site: Public comments and supporting materials

related to this notice can be found at <http://www.regulations.gov> by searching on Docket ID: NRC-2010-0294.

FOR FURTHER INFORMATION CONTACT: Duane White by telephone at 301-415-6272, E-mail: Duane.White@nrc.gov.

SUPPLEMENTARY INFORMATION:**Background**

In 2002, NRC developed a process for providing information to the Commission on significant nuclear materials issues and adverse licensee performance. This process was discussed in SECY-02-0216, "Proposed Process for Providing Information on Significant Nuclear Materials Issues and Adverse Licensee Performance," dated December 11, 2002. As part of this process, the staff developed criteria to determine nuclear material licensees with significant performance problems that would be discussed at the AARM. In 2008, the NRC revised the criteria to provide additional clarification regarding the criteria requirements and to incorporate NRC's current policy and procedures.

Discussion

NRC is preparing to revise the current criteria used to determine material licensees that will be discussed at the AARM. The agency currently identifies material licensees, including fuel cycle and Agreement State licensees, for AARM discussion based on operating performance, inspection results, and judgment of the severity of problems of safety performance. Although the revised AARM criteria will continue to be based upon the same principles as the existing criteria, the staff is proposing to include one additional element (i.e., criterion). This criterion focuses on those licensees previously discussed at the AARM who did not address or were ineffective in correcting their underlying issues.

Current Criteria for Determining Materials Licensees for the AARM

The current criteria for determining materials licensees for the AARM, as described in Enclosure 2 of SECY-08-0135, is as follows: (1) *Strategic Plan*—Licensee has an event that results in the failure to meet a strategic outcome for safety and security in the NRC Strategic Plan (NUREG-1614); (2) *Significant Issue or Event*—Licensee has an issue or event that results in an abnormal occurrence report to Congress (per NRC Management Directive 8.1), or a severity level I or II violation, as described in the NRC Enforcement Policy (including equivalent violations dispositioned by Alternative Dispute Resolution), or a level 3 or higher International Nuclear

Event Scale Report to the International Atomic Energy Agency (per NRC Management Directive 5.12), and there are unique or unusual aspects of the licensee's performance that warrant additional NRC oversight (e.g., a significant event, which requires an incident investigation team (IIT) or augmented inspection team (AIT)); or (3) *Performance Trend*—Licensee has multiple and/or repetitive significant program issues identified over more than one inspection, or inspection period, and the issues are supported by severity level I, II, or III violation, as described in the NRC Enforcement Policy (including equivalent violations dispositioned by Alternative Dispute Resolution). And, there are unique or unusual aspects of the licensee's performance that warrant additional NRC oversight (e.g., oversight panel formed for order implementation).

Proposed Criteria for Determining Materials Licensees for the AARM

The NRC is proposing the following revision to the existing criteria for determining materials licensees with significant performance issues: (1) *Strategic Plan*—Licensee has an event that results in the failure to meet a strategic outcome for safety and security in the NRC Strategic Plan (NUREG-1614); (2) *Significant Issue or Event*—Licensee has an issue or event that results in an abnormal occurrence report to Congress (per NRC Management Directive 8.1), or a severity level I or II violation, as described in the NRC Enforcement Policy (including equivalent violations dispositioned by Alternative Dispute Resolution), or a level 3 or higher International Nuclear Event Scale Report to the International Atomic Energy Agency (per NRC Management Directive 5.12), and there are unique or unusual aspects of the licensee's performance that warrant additional NRC oversight (e.g., a significant event, which requires an IIT or AIT); or (3) *Performance Trend*—Licensee has multiple and/or repetitive significant program issues identified over more than one inspection, or inspection period, and the issues are supported by severity level I, II, or III violation, as described in the NRC Enforcement Policy (including equivalent violations dispositioned by Alternative Dispute Resolution). And, there are unique or unusual aspects of the licensee's performance that warrant additional NRC oversight (e.g., oversight panel formed for order implementation); or (4) *Identified for Discussion at Previous AARM*—Licensee corrective actions did not address or were ineffective in correcting the underlying

issues that were previously discussed at the AARM.

You can find NRC's strategic plan (NUREG-1614) and the referenced management directives and enforcement policy on NRC's public document collections Web page at <http://www.nrc.gov/reading-rm/doc-collections/>.

Dated at Rockville, Maryland, this 25th day of August 2010.

For the Nuclear Regulatory Commission.

Cynthia A. Carpenter,

Deputy Director, Office of Federal and State Materials and Environmental Management Programs.

[FR Doc. 2010-22481 Filed 9-8-10; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2010-0288]

Draft Regulatory Guide, DG-1247, "Design-Basis Hurricane and Hurricane Missiles for Nuclear Power Plants" and Supporting Technical Basis Documents NUREG/CR 7004 and 7005

DG-1247 is a proposed new regulatory guide. Issuance and Availability; Correction and Comment Period Extension:

AGENCY: Nuclear Regulatory Commission.

ACTION: Notice of issuance; correction and comment period extension.

SUMMARY: On August 31, 2010 (75 FR 53352), the U.S. Nuclear Regulatory Commission (NRC) published a notice of issuance and availability of Draft Regulatory Guide (DG)—1247, "Design-Basis Hurricane and Hurricane Missiles for Nuclear Power Plants." This **Federal Register** Notice did not provide all the information regarding the supporting technical basis documents NUREG/CR 7004 and 7005. Due to this correction the comment period has been extended to November 5, 2010.

FOR FURTHER INFORMATION CONTACT:

Robert G. Carpenter, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, telephone (301) 251-7483, or e-mail Robert.Carpenter@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Introduction

The U.S. Nuclear Regulatory Commission (NRC) is issuing for public comment a draft guide in the agency's "Regulatory Guide" series and the supporting technical basis documents, NUREG/CR 7004 and 7005. This series

was developed to describe and make available to the public such information as methods that are acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques that the staff uses in evaluating specific problems or postulated accidents, and data that the staff needs in its review of applications for permits and licenses.

The draft regulatory guide (DG), entitled, "Design-Basis Hurricane and Hurricane Missiles for Nuclear Power Plants," is temporarily identified by its task number, DG-1247, which should be mentioned in all related correspondence. DG-1247 is a proposed new regulatory guide.

This guide describes a method that the NRC staff considers acceptable to support reviews of applications that the agency expects to receive for new nuclear reactor construction permits or operating licenses under 10 CFR Part 50; design certifications under 10 CFR Part 52, "Early Site Permits; Standard Design Certifications; and Combined Licenses for Nuclear Power Plants" (Ref. 9); and combined licenses under 10 CFR Part 52 that do not reference a standard design. Specifically, this regulatory guide provides new guidance that the staff of the NRC considers acceptable for use in selecting the design-basis hurricane windspeeds and hurricane-generated missiles that a new nuclear power plant should be designed to withstand to prevent undue risk to the health and safety of the public. This guidance applies to the contiguous United States but does not address the determination of the design-basis hurricane and hurricane missiles for sites located along the Pacific coast or in Alaska, Hawaii, or Puerto Rico; the NRC will evaluate such determinations on a case-by-case basis. This guide also does not identify the specific structures, systems, and components that should be designed to withstand the effects of the design-basis hurricane or should be protected from hurricane-generated missiles and remain functional. Nor does this guide address other externally generated hazards, such as aviation crashes, nearby accidental explosions resulting in blast overpressure levels and explosion-borne debris and missiles, and turbine missiles. NUREG/CR 7004 is the technical basis for regulatory guidance on design-basis hurricane-borne missile speeds and NUREG/CR 7005 is the technical basis for regulatory guidance on design-basis hurricane wind speeds for new nuclear power plants.