

standard drafting team “identified the portions of the collector system which consistently provide a reliability benefit to the interconnected transmission network and are easily identified within collector systems.”⁷ Thus, the

Commission estimates no material change in information collection because the engineering time needed to evaluate the collector system component included in the bulk electric system is a simple and straightforward

determination of whether the collector system aggregates to greater than 75 MVA.

*Estimate of Annual Burden:*⁸ The Commission estimates the public reporting burden as follows:

RD14-2-000 (FERC-725J)—REVISION TO THE DEFINITION OF BULK ELECTRIC SYSTEM

	Number of respondents ⁹ (A)	Number of responses per respondent (B)	Total number of responses (A) × (B) = (C)	Average burden hours per response (D)	Estimated total year 1 burden reduction (C) × (D)
Transmission Owners (System Review and List Creation)	333	1	333	– 1	– 333
Distribution Providers (System Review and List Creation)	554	1	554	– 1	– 554
Total	– 887

The total estimated decrease in cost burden to respondents (year 1 only) is \$53,220; [– 887 hours * \$60¹⁰ = – \$53,220].

Comments: Comments are invited on: (1) Whether the collection of information is necessary for the proper performance of the functions of the Commission, including whether the information will have practical utility; (2) the accuracy of the agency’s estimate of the burden and cost of the collection of information, including the validity of the methodology and assumptions used; (3) ways to enhance the quality, utility and clarity of the information collection; and (4) ways to minimize the burden of the collection of information on those who are to respond, including the use of automated collection techniques or other forms of information technology.

Dated: April 18, 2014.

Kimberly D. Bose,
Secretary.

[FR Doc. 2014-09342 Filed 4-23-14; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. RM13-5-000]

Version 5 Critical Infrastructure Protection Reliability Standards; Supplemental Notice of Agenda and Discussion Topics for Staff Technical Conference

This notice establishes the agenda and topics for discussion at the technical

conference to be held on April 29, 2014 to discuss issues related to Critical Infrastructure Protection Issues Identified in Order No. 791. The technical conference will be held from 10:00 a.m. and ending at approximately 4:30 p.m. (Eastern Time) in the Commission Meeting Room at the Commission’s headquarters, 888 First Street NE., Washington, DC. The technical conference will be led by Commission staff. All interested parties are invited to attend, and registration is not required.

The topics and related questions to be discussed during this conference are attached. The purpose of the technical conference is to facilitate a structured dialogue on operational and technical issues identified by the Commission in the Critical Infrastructure Protection (CIP) version 5 Standards Final Rule. Prepared remarks will be presented by invited panelists.

There will be no webcast of this event. However, it will be transcribed. Transcripts of the meeting/conference will be immediately available for a fee from Ace-Federal Reporters, Inc. (202-347-3700 or 1-800-336-6646).

FERC conferences are accessible under section 508 of the Rehabilitation Act of 1973. For accessibility accommodations please send an email to accessibility@ferc.gov or call toll free (866) 208-3372 (voice) or (202) 502-8659 (TTY), or send a fax to (202) 208-2106 with the requested accommodations.

There is no fee for attendance. However, members of the public are encouraged to preregister online at:

<https://www.ferc.gov/whats-new/registration/04-29-14-form.asp>.

For more information about the technical conference, please contact: Sarah McKinley, Office of External Affairs, 202-502-8368, sarah.mckinley@ferc.gov.

Dated: April 17, 2014.

Kimberly D. Bose,
Secretary.



Critical Infrastructure Protection Issues Identified in Order No. 791

RM13-5-000

April 29, 2014

Agenda

10:00–10:15 a.m. Welcome and Opening Remarks by Commission Staff

Introduction

In Order No. 791, the Commission approved the Version 5 Critical Infrastructure Protection (CIP) Reliability Standards, CIP-002–5 through CIP-011–1 (CIP version 5 Standards), submitted by the North American Electric Reliability Corporation (NERC).¹ Order No. 791 directed Commission staff to convene a staff-led technical conference, within

⁷ NERC Petition at 16.

⁸ The Commission defines burden as the total time, effort, or financial resources expended by persons to generate, maintain, retain, or disclose or provide information to or for a Federal agency. For further explanation of what is included in the information collection burden, reference 5 Code of Federal Regulations 1320.3.

⁹ The number of respondents for transmission owners and distribution providers is based on the NERC Compliance Registry referenced in Order No. 773.

¹⁰ The estimate for cost per hour for an electrical engineer is \$60 (the average salary plus benefits) according to the Bureau of Labor Statistics at http://bls.gov/oes/current/naics2_22.htm.

¹ Version 5 Critical Infrastructure Protection Reliability Standards, Order No. 791, 78 FR 72,755 (Dec. 3, 2013), 145 FERC ¶ 61,160 (2013), *order on reh'g*, Order No. 791-A, 146 FERC ¶ 61,188 (2014).

180 days from the issuance date of the Final Rule, to examine several of the technical issues identified therein.² The purpose of this conference is to obtain further information as to: (1) The adequacy of the approved CIP version 5 Standards' protections for Bulk-Power System data being transmitted over data networks; (2) whether additional definitions and/or security controls are needed to protect Bulk-Power System (BPS) communications networks, including remote systems access; and (3) the functional differences between the respective methods utilized for identification, categorization, and specification of appropriate levels of protection for cyber assets using CIP version 5 Standards as compared with those employed within the National Institute of Standards and Technology (NIST) Security Risk Management Framework.

Panel 1

10:15–11:45 a.m. The Adequacy of the CIP version 5 Standards for Protection of BPS Communication Networks

The Commission seeks information about the adequacy of the approved CIP version 5 Standards for protecting data being transmitted over BPS communication networks. Panelists are encouraged to address:

- The vulnerabilities that BPS communication networks may be facing and how effectively they are being protected against these risks by the currently enforced CIP Reliability Standards.
- The adequacy of the approved CIP version 5 Standards security controls to protect BPS communication networks against current and projected vulnerabilities.
- The types of physical or logical controls that are currently being applied to protect BPS communication networks and the adequacy of these controls to address the protection of: (1) non-routable protocols, (2) serial communication links, (3) non-programmable components, (4) remote access processes and devices, and (5) data in motion.
- For each of the topics above, the panelists should address whether there are gaps in the current CIP version 5 Standards that could be addressed, and suggest recommendations for adjustment of the CIP version 5 Standards to address any gaps.

Panelists:

- Dan Skaar, President and CEO, Midwest Reliability Organization

- Kevin Perry, Director, CIP, Southwest Power Pool Regional Entity
 - Richard Dewey, Senior Vice President & CIO, NYISO
 - Steven Parker, President, EnergySec
 - Mikhail Falkovich, Manager NERC/CIP Compliance, PSEG; Speaking on behalf of Electric Power Supply Association (EPSA)
 - Tobias Whitney, Manager, CIP Compliance, North America Electric Reliability Corporation (NERC)
- 11:45–1:00 p.m. Lunch

Panel 2

1:00–2:30 p.m. Need for Additional Definitions or Controls for CIP Reliability Standards

The Commission seeks information on whether additional definitions and/or security controls are needed to protect BPS communications networks, including remote systems access.

Panelists are encouraged to address:

- Whether the NERC Glossary of Terms needs either new definitions, or modifications of current definitions, to ensure adequate protection of BPS communication networks.
- The types of physical or logical controls that may be needed to protect BPS communication network components communicating via non-routable protocols, or through serial communication links.
- The types of physical or logical controls that may be needed to protect non-programmable components of data communications networks (e.g., cabling).
- The types of physical or logical controls that may be needed to address the cybersecurity needs of remote access processes and devices.
- How the confidentiality, integrity, and availability of data in motion (i.e., being transmitted) over BPS communication networks can be ensured physically and/or electronically.
- To what extent different types of encryption technology can be effectively employed on BPS communication networks without adversely affecting BPS operations.
- For each of the topics above, the panelists should address whether there are gaps in the current CIP version 5 Standards that could be addressed, and suggest recommendations for adjustment of the CIP version 5 Standards to address any gaps.

Panelists:

- Kevin Perry, Director, CIP, Southwest Power Pool Regional Entity
- Richard Kinast, Mgr. Standards Compliance, Orlando Utilities Commission

- David Dekker, Cyber Security Standards Manager, Pepco Holdings Inc.
 - Dr. Andrew Wright, N-Dimension Solutions
 - Andrew Ginter—VP Industrial Security, Waterfall Security Solutions
 - David Batz, Director, Cyber & Infrastructure Security, Edison Electric Institute
- 2:30–2:45 p.m. Break

Panel 3

2:45–4:15 p.m. NIST Frameworks Discussion

The Commission seeks information on functional differences between the respective methods used for identification, categorization, and specification of appropriate levels of protection for cyber assets using CIP version 5 Standards as compared with those employed within other cyber security frameworks, including the NIST Security Risk Management Framework (RMF) and the recently-released Framework for Improving Critical Infrastructure Cybersecurity (NIST Cyber Security Framework). Panelists are encouraged to address:

- The functional differences on how each framework approaches asset identification to address emerging threats, risks, and vulnerabilities. Panelists may suggest how the CIP version 5 Standards could be adjusted to address any concern or weakness, or explain whether or not the approaches identified in the NIST Security Risk Management Framework and the NIST Cyber Security Framework are more appropriate for protecting BPS critical infrastructure.
- Whether it is prudent to use only facility ratings, (e.g., power, voltage, operating conditions), to identify and categorize BES cyber assets that are subject to CIP Standards in CIP-002-5. Panelists may suggest the inclusion of additional attributes, (e.g., data sensitivity) or recommend adjustments to the bright-line criteria for ensuring accurate identification and categorization of BES cyber assets. Panelists are encouraged to identify potential issues in Reliability Standard CIP-002-5 that could hinder the implementation of the CIP version 5 Standards (e.g. any issues relating to NERC Glossary of Terms definitions, CIP-002-5 criteria or impact levels).
- Comparisons between the CIP version 5 Standards security controls and the security controls of the two NIST Frameworks and the identification of specific security controls or control objectives that should be considered in future revisions of CIP standards.

² *Id.* at PP 7, 150, and 225.

Panelists:

- Patrick Miller, Managing Partner, The Anfield Group
- Brent Castagnetto, Manager, Cyber Security Audits & Investigations, WECC
- Gerald Mannarino, Director, Computer System Engineering, New York Power Authority
- Melanie Seader, Senior Cyber & Infrastructure Security Analyst, Edison Electric Institute
- Jason Christopher, Technical Lead, Cyber Security Capabilities & Risk Management, U.S. Department of Energy

4:15–4:30 p.m. Wrap-Up

[FR Doc. 2014–09331 Filed 4–23–14; 8:45 am]

BILLING CODE 6717–01–P

DEPARTMENT OF ENERGY**Federal Energy Regulatory Commission**

[Reliability Technical Conference; Docket No. AD14–9–000]

Notice of Technical Conference

Take notice that the Federal Energy Regulatory Commission (Commission) will hold a Technical Conference on Tuesday, June 10, 2014 from 8:45 a.m. to 5:00 p.m. This Commissioner-led conference will be held in the Commission Meeting Room at the Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. The conference will be open for the public to attend. Advance registration is not required, but is encouraged. Attendees may register at the following Web page: <https://www.ferc.gov/whats-new/registration/06-20-14-form.asp>.

The purpose of the conference is to discuss policy issues related to the reliability of the Bulk-Power System. A more formal agenda will be issued at a later date.

Information on this event will be posted on the Calendar of Events on the Commission's Web site, www.ferc.gov, prior to the event. The conference will also be Webcast. Anyone with Internet access who desires to listen to this event can do so by navigating to www.ferc.gov's Calendar of Events and locating this event in the Calendar. The event will contain a link to the webcast. The Capitol Connection provides technical support for webcasts and offers the option of listening to the meeting via phone-bridge for a fee. If you have any questions, visit www.CapitolConnection.org or call 703–993–3100.

Commission conferences are accessible under section 508 of the Rehabilitation Act of 1973. For accessibility accommodations, please send an email to accessibility@ferc.gov or call toll free 1–866–208–3372 (voice) or 202–502–8659 (TTY), or send a FAX to 202–208–2106 with the required accommodations.

For more information about this conference, please contact: Sarah McKinley, Office of External Affairs, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426, (202) 502–8368, sarah.mckinley@ferc.gov.

Dated: April 16, 2014.

Kimberly D. Bose,
Secretary.

[FR Doc. 2014–09339 Filed 4–23–14; 8:45 am]

BILLING CODE 6717–01–P

DEPARTMENT OF ENERGY**Federal Energy Regulatory Commission****Notice of FERC Staff Attendance at the Entergy Regional State Committee Meeting**

The Federal Energy Regulatory Commission (Commission) hereby gives notice that members of its staff may attend the meeting noted below. Their attendance is part of the Commission's ongoing outreach efforts.

Entergy Regional State Committee

April 25, 2014 (9:30 A.M.–1:30 P.M.)

This meeting will be held at the Capital Hotel, 111 West Markham Street, Little Rock, AR 72201.

The discussions may address matters at issue in the following proceedings:

- Docket No. EL01–88: Louisiana Public Service Commission v. Entergy Services, Inc.*
- Docket No. EL09–50: Louisiana Public Service Commission v. Entergy Services, Inc.*
- Docket No. EL09–61: Louisiana Public Service Commission v. Entergy Services, Inc.*
- Docket No. EL10–55: Louisiana Public Service Commission v. Entergy Services, Inc.*
- Docket No. EL10–65: Louisiana Public Service Commission v. Entergy Services, Inc.*
- Docket No. EL11–57: Louisiana Public Service Commission v. Entergy Services, Inc., et al.*
- Docket No. EL11–34: Midwest Independent Transmission System Operator, Inc. v. Southwest Power Pool, Inc.*

Docket No. EL11–63: Louisiana Public Service Commission v. Entergy Services, Inc.

Docket No. EL11–65: Louisiana Public Service Commission v. Entergy Services, Inc.

Docket No. EL13–41: Occidental Chemical Company v. Midwest Independent System Transmission Operator, Inc.

Docket No. EL13–43: Council of the City of New Orleans, Mississippi Public Service Commission, Arkansas Public Service Commission, Public Utility Commission of Texas, Louisiana Public Service Commission

Docket No. EL14–21: Southwest Power Pool, Inc. v. Midcontinent Independent System Operator, Inc.

Docket No. EL11–30: Midcontinent Independent System Operator, Inc. v. Southwest Power Pool, Inc.

Docket No. ER05–1065: Entergy Services, Inc.

Docket No. ER07–682: Entergy Services, Inc.

Docket No. ER07–956: Entergy Services, Inc.

Docket No. ER08–1056: Entergy Services, Inc.

Docket No. ER09–1224: Entergy Services, Inc.

Docket No. ER10–794: Entergy Services, Inc.

Docket No. ER10–1350: Entergy Services, Inc.

Docket No. ER10–2001: Entergy Arkansas, Inc.

Docket No. ER10–3357: Entergy Arkansas, Inc.

Docket No. ER11–2161: Entergy Texas, Inc.

Docket No. ER12–480: Midwest Independent Transmission System Operator, Inc.

Docket No. ER12–1384: Entergy Arkansas, Inc.

Docket No. ER12–1385: Entergy Gulf States Louisiana, L.L.C.

Docket No. ER12–1386: Entergy Louisiana, LLC

Docket No. ER12–1387: Entergy Mississippi, Inc.

Docket No. ER12–1388: Entergy New Orleans, Inc.

Docket No. ER12–1390: Entergy Texas, Inc.

Docket No. ER12–1428: Entergy Arkansas, Inc.

Docket No. ER13–432: Entergy Services, Inc.

Docket No. ER13–769: Entergy Arkansas, Inc. and Entergy Mississippi, Inc.

Docket No. ER13–770: Entergy Arkansas, Inc. and Entergy Louisiana, LLC.